CERTIFICATE OF COMPLIANCE

Certificate Number	E341867
Report Reference	E341867-20220922
Date	2022-September-21
Issued to:	Wieland Electric GmbH Brennerstrasse 10-14 Bamberg 96052 DE
This is to certify that representative samples of	MULTI-POINT INTERCONNECTION POWER CABLE ASSEMBLIES FOR INDUSTRIAL MACHINERY - COMPONENT See Addendum Page for Product Designation(s).
	Have been evaluated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.
Standard(s) for Safety:	UL 2237, Multi-Point Interconnection Power Cable Assemblies for Industrial Machinery CSA C22.2 No 182.3-16, Special Use Attachment Plugs, Receptacles and Connectors
Additional Information:	See the UL Online Certifications Directory at https://iq.ulprospector.com for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Recognized Component Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number	E341867
Report Reference	E341867-20220922
Date	2022-September-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Connector, Revos Basic series, screw connection:

Male Inserts – Cat. Nos. BAS STS; followed by 6, 10, 16 or 24; followed by additional alphanumeric suffixes

Female Inserts – Cat. Nos. BAS BUS; followed by 6, 10, 16 or 24; followed by additional alphanumeric suffixes

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number E341867
Report Reference E341867-20220922
Date 2022-September-21

RATINGS:

Series	Number of Poles Live/Ground Power	Tightening Torque (Nm)	Wire Size (AWG)	Current (A)	Voltage (V AC)
BAS STS / BUS; followed by 6, 10, 16 or 24; followed by additional alphanumeric suffixes	6/1 and 10/1	0.5 - 0.7	12	**16**	600
			14	14	
			16	**11**	
			18	**7**	
	16/1		12	15	
			14	12	
			16	**10**	
			18	**7**	
	24/1		12	15	
			14	12	
			16	9	
			18	6	

Interruption of Current

These devices are not suitable for interrupting the flow of current by connecting or disconnecting the mating connector.

Short Circuit

Short circuit testing was conducted at 5,000 A at 600 Vac.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/