

CERTIFICATE OF COMPLIANCE

Certificate Number E341867
Report Reference E341867-20220920
Date 2022-September-21

Issued to: Wieland Electric GmbH
Brennerstrasse 10-14
Bamberg 96052 DE

**This is to certify that
representative samples of**

MULTI-POINT INTERCONNECTION POWER CABLE
ASSEMBLIES FOR INDUSTRIAL MACHINERY -
COMPONENT

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the component requirements in the Standard(s) indicated on this Certificate. UL Recognized components are incomplete in certain constructional features or restricted in performance capabilities and are intended for installation in complete equipment submitted for investigation to UL LLC.


Standard(s) for Safety: UL 2237, Multi-Point Interconnection Power Cable Assemblies for Industrial Machinery
CSA C22.2 No 182.3-16, Special Use Attachment Plugs, Receptacles and Connectors

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Recognized Component Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E341867
Report Reference E341867-20220920
Date 2022-September-21

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements


Connector, Revos Power series:

Male Inserts – Cat. Nos. POW STS; followed by 6 6,0; followed by additional alphanumeric suffixes

Male Inserts – Cat. Nos. POW STS 4 16 64; followed by additional alphanumeric suffixes

Female Inserts – Cat. Nos. POW BUS; followed by 6 6,0; followed by additional alphanumeric suffixes

Female Inserts – Cat. Nos. POW BUS 4 16 64; followed by additional alphanumeric suffixes



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E341867
Report Reference E341867-20220920
Date 2022-September-21

RATINGS:


Cat. Nos.	Number of Poles Live/Ground Power	Tightening Torque (Nm)	Wire Size (AWG)	Current (A)	Voltage (V AC)
POW STS / BUS; followed by 6 6,0; followed by additional alphanumeric suffixes	6/1	1-2 - 1.6	8	30	600
			12	22	
POW STS / BUS 4 16 64; followed by additional alphanumeric suffixes	4/1	2.5 - 3.0	8	35	600

Interruption of Current

These devices are not suitable for interrupting the flow of current by connecting or disconnecting the mating connector.

Short Circuit

Short circuit testing was conducted at 65,000 A at 600 Vac.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

