Certificate of Compliance

Certificate: 80168523 **Master Contract:** 254117

Project: 80168523 **Date Issued:** May 9, 2023

Issued to: **Wieland Electric GmbH**
Brennerstrasse 10-14
Bamberg, Bavaria 96052
Germany

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only

C US

Issued by: Tammy Klinger
Tammy Klinger

PRODUCTS

C321107 INDUSTRIAL CONTROL EQUIPMENT – Miscellaneous Apparatus
C321187 INDUSTRIAL CONTROL EQUIPMENT – Miscellaneous Apparatus – Certified to US Standards

Safety switch with separate actuator:

Models	Input Voltage (V)	Input Power (VA)	Frequency (Hz)	Contact Rating	Enclosure Type
SIN Series	24 V	6.7	60 (for ac voltage)	30 V / 2 A (General Use) or B300/R300	6 “indoor use only”
	120 Vac	7.0	60	30 V / 2 A (General Use) or B300/R300	6 “indoor use only”
	230 Vac	7.1	60	30 V / 2 A (General Use) or B300/R300	6 “indoor use only”

© 2018 CSA Group. All rights reserved.

Certificate: 80168523 **Master Contract:** 254117

Project: 80168523 **Date Issued:** May 9, 2023

APPLICABLE REQUIREMENTS

CSA C22.2 NO. 14-18 – Industrial Control Equipment

UL 508 (Eighteenth Ed.) – Industrial Control Equipment

Notes:

Products certified under Class C321107 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

© 2018 CSA Group. All rights reserved.