CERTIFICATE OF COMPLIANCE

Certificate Number	20171218-E480715
Report Reference	E480715-20151208
Issue Date	2017-DECEMBER-18
Issued to:	WIELAND ELECTRIC GMBH BRENNERSTRASSE 10-14 96052 BAMBERG, GERMANY
This is to certify that representative samples of	Modular Cable System Assemblies and Fittings for Industrial Control, Signal and Power Distribution USL - Modular Cable System Assemblies and Fittings for Industrial Control, Signal and Power Distribution, Catalog No. podis CON Male-to-Male configurations are not covered due to accessibility of live parts. (See following pages for additional information.) Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.
Standard(s) for Safety:	UL 2875, Outline of Investigation for Modular Cable System Assemblies and Fittings for Industrial Control, Signal and Power Distribution
Additional Information:	See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number 20171218-E480715
Report Reference E480715-20151208
Issue Date 2017-DECEMBER-18

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Modular Cable System — Designation podis Con

Cable Type	Ratings			
	Circuit 1		Circuit 2	
TC- ER, MC, AC, Other	Volts AC/DC	Amps	Volts AC/DC	Amps
Tray Cable part number00.729.0504.1	600 Vac	20	600 Vac, or 48 Vdc	20

Modular Cable System Connectors and Devices for use with Modular Cable System - Designation podis Con

Description Type Designation	Ratings			Environmental Rating	Additional Information
	Circuit 1	Circuit 2	Circuit 3		
Tray Cable, part number 00.729.0504.1	600 Vac, 20A	600 Vac, or 48 Vdc, 20A	N/A	N/A	Only for use with Tray Cable part number 00.729.0504.1
Feeder Tap System, FCS 4 7 SI BU	600 Vac, 20A	600 Vac, or 48 Vdc, 20A	N/A	N/A	N/A
Terminal Block, FCS 4 7 SA SA	600 Vac, 20A	600 Vac, or 48 Vdc, 20A	N/A	N/A	N/A
Feeder Tap System, FCS 4 7 ST SA	600 Vac, 20A	600 Vac, or 48 Vdc, 20A	N/A	N/A	N/A
Low Voltage Class 2 LED Luminaries, LED FCS24	N/A	Maximum input voltage 24 Vdc, input current 350 mA	N/A	N/A	N/A

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number 20171218-E480715
Report Reference E480715-20151208
Issue Date 2017-DECEMBER-18

Description Type Designation	Ratings			Environmental Rating	Additional Information
	Circuit 1	Circuit 2	Circuit 3		
Low Voltage Class 2 LED Luminaries, LED RST	N/A	Maximum input voltage 24 Vdc, input current 350 mA	N/A	N/A	N/A
Low Voltage Class 2 LED Luminaries, LED FCS 24	N/A	Maximum input voltage 24 Vdc, input current 350 mA	N/A	N/A	N/A
Receptacle plug, FCS NEMA 5-20 GFCI	125 Vac, 20A	N/A	N/A	N/A	N/A
Connector Module, FCS 4 7 SI FK	600 Vac, 20A	600 Vac, or 48 Vdc, 20A	N/A	N/A	N/A
Connector Module, FCS 4 7 SI FK FM	600 Vac, 20A	600 Vac, or 48 Vdc, 20A	N/A	N/A	N/A
Low Voltage Class 2 LED Luminaries, PODIS LED RST	N/A	Maximum input voltage 24 Vdc, input current 750 mA	N/A	N/A	N/A
Low Voltage Class 2 LED Luminaries, PODIS LED FCS	N/A	Maximum input voltage 24 Vdc, input current 750 mA	N/A	N/A	N/A
LED Portable Luminaries, PODIS LED RST	Maximum input voltage 100-240 V, input current 350 mA	N/A	N/A	N/A	N/A

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

CERTIFICATE OF COMPLIANCE

Certificate Number 20171218-E480715
Report Reference E480715-20151208
Issue Date 2017-DECEMBER-18

Description Type Designation	Ratings			Environmental Rating	Additional Information
	Circuit 1	Circuit 2	Circuit 3		
LED Luminaries for Busway Feeders, PODIS LED FCS	Maximum input voltage 100-240 V, input current 350 mA	N/A	N/A	N/A	N/A
Cable End Cap, part number Z5.562.7553.1	N/A	N/A	N/A	N/A	N/A
Cable Feed Through - FLACHLEITUNG	N/A	N/A	N/A	N/A	N/A
Cable Clips	N/A	N/A	N/A	N/A	N/A

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/