

Certificate of Compliance

Certificate Number(s):

UL-US-2122777-3

Report Reference:

E169904-20210420

Issue Date:

2026-03-24

Issued to:

Wieland Electric GmbH

Brennerstrasse 10-14, Bamberg, 96052, DE

This certificate confirms that representative samples of:

NMTR - Power Circuit and Motor-mounted Apparatus

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 508, 18th Ed., Issue Date: 2018-03-30, Revision Date: 2021-07-08

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch

UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-2122777-3
Report reference: E169904-20210420
Issue Date: 2026-03-24

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Power Circuit and Motor Mounted Apparatus

Model(s): Podis FCS E16 5 SASA *ST may be followed by alphanumeric characters not relating to safety.*

Model(s): Podis FCS E16 5 SA SA, *may be followed by M, may be followed by MMS, followed by 50G, 63G, 50K or 63K.*

Model(s): Podis 16 5 SA *may be followed by SA_BB or SA_SB, may be followed by alphanumeric characters not relating to safety.*

Model(s): FH *2XFC7 may be followed by alphanumeric characters not relating to safety.*

ELECTRICAL RATINGS:

FH 2XFC7 model rated 600VAC, 48VDC 40A input with 2x20A outputs.

All other models:
600VAC, 75A
48VDC, 75A

ENVIRONMENTAL RATINGS:

Ambient temperature rating: 40°C.

Type 4 only for Podis FCS 16 5 SA.. models.

Type 1 only for Podis FCS E16 5 SASA ST and FH 2XFC7 models.

Certificate of Compliance

Certificate Number(s):

UL-CA-2118618-3

Report Reference:

E169904-20210420

Issue Date:

2026-03-24

Issued to:

Wieland Electric GmbH
Brennerstrasse 10-14, Bamberg, 96052, DE

This certificate confirms that representative samples of:

NMTR7 - Power Circuit and Motor-mounted Apparatus Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 No. 14, Edition 13, Issue Date 2018-03, Revision Date 2022-06

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-2118618-3
Report reference: E169904-20210420
Issue Date: 2026-03-24

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Power Circuit and Motor Mounted Apparatus

Model(s): Podis FCS E16 5 SASA ST may be followed by alphanumeric characters not relating to safety.

Model(s): Podis FCS E16 5 SA SA, may be followed by M, may be followed by MMS, followed by 50G, 63G, 50K or 63K.

Model(s): Podis 16 5 SA may be followed by SA_BB or SA_SB, may be followed by alphanumeric characters not relating to safety.

Model(s): FH 2XFC7 may be followed by alphanumeric characters not relating to safety.

ELECTRICAL RATINGS:

FH 2XFC7 model rated 600VAC, 48VDC 40A input with 2x20A outputs.

All other models:

600VAC, 75A

48VDC, 75A

ENVIRONMENTAL RATINGS:

Ambient temperature rating: 40°C.

Type 4 only for Podis FCS 16 5 SA.. models.

Type 1 only for Podis FCS E16 5 SASA ST and FH 2XFC7 models.

CERTIFICATE OF COMPLIANCE

Certificate Number E480715
Report Reference E480715-20210520
Date 2021-June-01

Issued to: Wieland Electric GmbH
BRENNERSTRASSE 10-14
BAMBERG96052 DE

**This is to certify that
representative samples of** MODULAR CABLE SYSTEM ASSEMBLIES AND
FITTINGS FOR INDUSTRIAL CONTROL, SIGNAL AND
POWER DISTRIBUTION

Catalog Nos. podis FCS 16 5 SA SA followed by additional
letters or numbers or a combination of both, podis FCS 16 5
SI SA M25, podis FCS 16 5 SI SA M32, podis FCS 16 5 SI
SA RST.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL2875, OUTLINE OF INVESTIGATION FOR MODULAR
CABLE SYSTEM ASSEMBLIES AND FITTINGS FOR
INDUSTRIAL CONTROL, SIGNAL AND POWER
DISTRIBUTION.

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number E480715
Report Reference E480715-20210520
Date 2021-June-01

RATINGS:

Cat Nos/Series	Number of Live Poles	Number of Ground Poles	AWG	Voltage (V) Max	Current (A) Max
podis FCS 16 5 SI SA M25 and podis FCS 16 5 SI SA M32	4	1	6 AWG (flat cable)	600 Vac or 48 VDC	41
	4	1	6 or 8 AWG (round cable)	600 Vac or 48 VDC	41
podis FCS 16 5 SA SA followed by additional letters or numbers or a combination of both (feeder box)	4	1	6 AWG (flat cable) 6AWG - 2/0 AWG (round cable)	600 Vac or 48 VDC	65
podis FCS 16 5 SI SA RST	4	1	6 AWG (flat cable) 14 AWG (round cable)	600 Vac	20
*podis FCS 16 5 SI SA M25 and podis FCS 16 5 SI SA M32 (ac/dc circuits combined 2 for ac circuit 2 for dc circuit 1 grounding)	2 for ac circuit	1	6 AWG (flat cable) 8 AWG (round cable)	120 Vac	41
	2 for dc circuit			12 Vdc	
podis FCS 16 5 SI SA M25 and podis FCS 16 5 SI SA M32 (ac/dc circuits combined 2 for ac circuit 2 for dc circuit)	2 for ac circuit	1	6 AWG (flat cable) 8 AWG (round cable)	347 Vac	41
	2 for dc circuit			48 Vdc	41



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>