Certificate of Compliance

Certificate Number(s):

UL-US-2122777-3

Report Reference:

E169904-20210420

Issue Date:

2026-03-24

Issued to:

Wieland Electric GmbH
Brennerstrasse 10-14, Bamberg, 96052, DE

This certificate confirms that representative samples of:

NMTR - Power Circuit and Motor-mounted Apparatus

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 508, 18th Ed., Issue Date: 2018-03-30, Revision Date: 2021-07-08

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-2122777-3
Report reference: E169904-20210420
Issue Date: 2026-03-24

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Power Circuit and Motor Mounted Apparatus

Model(s): Podis FCS *E16 5 SASA ST may be followed by alphanumeric characters not relating to safety.*

Model(s): Podis FCS E16 5 SA *SA, may be followed by M, may be followed by MMS, followed by 50G, 63G, 50K or 63K.*

Model(s): Podis 16 5 SA *may be followed by SA_BB or SA_SB, may be followed by alphanumeric characters not relating to safety.*

Model(s): FH 2XFC7 *may be followed by alphanumeric characters not relating to safety.*

ELECTRICAL RATINGS:

FH 2XFC7 model rated 600VAC, 48VDC 40A input with 2x20A outputs.

All other models:
600VAC, 75A
48VDC, 75A

ENVIRONMENTAL RATINGS:

Ambient temperature rating: 40ºC.

Type 4 only for Podis FCS 16 5 SA.. models.
Type 1 only for Podis FCS E16 5 SASA ST and FH 2XFC7 models.

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.

Certificate of Compliance

Certificate Number(s):

UL-CA-2118618-3

Report Reference:

E169904-20210420

Issue Date:

2026-03-24

Issued to:

Wieland Electric GmbH
Brennerstrasse 10-14, Bamberg, 96052, DE

This certificate confirms that representative samples of:

NMTR7 - Power Circuit and Motor-mounted Apparatus Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 No. 14, Edition 13, Issue Date 2018-03, Revision Date 2022-06

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Manager

UL Solutions

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-CA-2118618-3
Report reference: E169904-20210420
Issue Date: 2026-03-24

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Power Circuit and Motor Mounted Apparatus

Model(s): Podis FCS *E16 5 SASA ST may be followed by alphanumeric characters not relating to safety.*

Model(s): Podis FCS E16 5 SA *SA, may be followed by M, may be followed by MMS, followed by 50G, 63G, 50K or 63K.*

Model(s): Podis 16 5 SA *may be followed by SA_BB or SA_SB, may be followed by alphanumeric characters not relating to safety.*

Model(s): FH 2XFC7 *may be followed by alphanumeric characters not relating to safety.*

ELECTRICAL RATINGS:

FH 2XFC7 model rated 600VAC, 48VDC 40A input with 2x20A outputs.

All other models:
600VAC, 75A
48VDC, 75A

ENVIRONMENTAL RATINGS:

Ambient temperature rating: 40ºC.

Type 4 only for Podis FCS 16 5 SA.. models.
Type 1 only for Podis FCS E16 5 SASA ST and FH 2XFC7 models.

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.