



Certificate of Compliance

Certificate: 70000439

Master Contract: 165750

Project: 70000439

Date Issued: May 21, 2013

Issued to: Wieland Electric GmbH
Brennerstrasse 10-14
Bamberg/Bayern, 96052
GERMANY

The products listed below are eligible to bear the CSA Mark shown



Marco Kloppenborg
Issued by: Marco Kloppenborg

PRODUCTS

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

Certificate: 70000439

Master Contract: 165750

Project: 70000439

Date Issued: May 21, 2013

Terminal Blocks with screw clamp connection, suitable for mounting on a DIN-rail, for solid and stranded insulated conductors:

Cat. No.	Voltage [V]	Group	Current [A]	Wire range [AWG]	Torque [Nm]	Remarks
WT 2.5	600	C	20	26-12, 2x26 - 2x16	0,4	
WT 2.5 PE				26-12, 2x26 - 2x16	0,4	PCTB
WT 4	600	C	30	26-10, 2x26 - 2x14	0,5	
WT 4 PE				26-10, 2x26 - 2x14	0,5	PCTB
WT 4 D1/2	300	C	30	26-10, 2x26 - 2x14	0,5	
WT 4 D1/2 PE				26-10, 2x26 - 2x14	0,5	PCTB
WT 4 D2/2	300	C	30	26-10, 2x26 - 2x14	0,5	
WT 4 D2/2 PE				26-10, 2x26 - 2x14	0,5	PCTB
WT 4 E	300	C	30	26-10, 2x26 - 2x14	0,5	
WT 4 E PE				26-10, 2x26 - 2x14	0,5	PCTB
WT 4 E VB	300	C	30	26-10, 2x26 - 2x14	0,5	
WT 4 TKM	300	C	16	26-10, 2x26 - 2x14	0,5	
WT 6	600	C	50	24-8, 2x24 - 2x12	1,2	
WT 6 PE				24-8, 2x24 - 2x12	1,2	PCTB
WT 16	600	C	85	14-4, 2x14 - 2x8	2	
WT 16 PE				14-4, 2x14 - 2x8	2	PCTB



Certificate: 70000439

Project: 70000439

Master Contract: 165750

Date Issued: May 21, 2013

Accessories that may be used with terminal block series WT:

Cat. No.	Voltage [V]	Group	Remarks
AP WT 2.5-10	600	C	Endplate
AP WT D1/2	600	C	Endplate
AP WT D2/2	600	C	Endplate
AP WT 4 E	600	C	Endplate
AP WT 16	600	C	Endplate
TW WT 2.5-10	600	C	Partition plate
TW WT 4 E	600	C	Partition plate
TW WT 4 E - WT 16	600	C	Partition plate
IVB WKF 2.5-2..10	600	C	Cross connector
IVB WKF 4-2..10	600	C	Cross connector
IVB 0,5 WKF 4-2..12	300	C	Cross connector
IVB 1 WKF 4-2..12	300	C	Cross connector
IVB WKFN 6-2..10	600	C	Cross connector
IVB WKF 6 TK-2..10	600	C	Cross connector
IVB WKFN 16-2	600	C	Cross connector
AD WT 2.5	600	C	Cover
AD WT 4	600	C	Cover
AD WT 6-10	600	C	Cover
AD WT 16	600	C	Cover
PS WKC/F	600	C	Test plug
9708/2S/35	600	C	End clamp
WEF 1/35	600	C	End clamp
WE 1/U	600	C	End clamp

Notes:

1. Certified as a component for use only where the suitability of the final combination is determined by CSA Group or another NRTL.
2. Suffixes may be added to the Catalogue numbers, to denote color and other mechanical variations not affecting the electrical properties.
3. CSA Marking of cross connectors and the test plug is on the package instead of the product, in accordance with DQD 311. Refer to Certification Report for detail.



Certificate: 70000439

Project: 70000439

Master Contract: 165750

Date Issued: May 21, 2013

APPLICABLE REQUIREMENTS

CSA C22.2 No. 0-10 - General Requirements Canadian Electrical Code, Part II

CSA C22.2 No. 158-10 - Terminal Blocks

MARKINGS

(a) The following marking details are molded in or ink-stamped on each device:

- Submitter's name, trade name or trade mark;
- CSA monogram;
- Basic catalogue number;
- Maximum voltage (if applicable);
- Ampere rating (if applicable);
- Wire range (if applicable).

(b) The complete catalogue number is provided on the smallest packaging unit.

(c) Torque values (if applicable) are provided in the manufacturer's catalogue.

Marking on the cross connectors and the test plug may be omitted with reference to DQD 311, sections 3.3/3.4 and DQD 535.01, if they are applied to the smallest packaging unit and the mating connectors are marked appropriately.



Supplement to Certificate of Compliance

Certificate: 70000439

Master Contract: 165750

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70000439	May 21, 2013	Original Certification of terminal blocks series WT. According to CSA C22.2 No. 158-10.