

MASTER CONTRACT: 165750

REPORT: 70068793

PROJECT: 70156884

Edition 1: December 22, 2016; Project 70068793 – Arnhem
Issued by J.R. Holtman

Edition 2: September 27, 2017; Project 70156884 - Arnhem
Issued by J.R. Holtman

Report pages reissued

Contents: Certificate of Compliance - Page 1 to 2
Supplement to Certificate of Compliance - Page 1
Description and Tests - Pages 1 to 8
Att1 Test Results Part A - 1 to 20
Att1 Test Results Part B - 1 to 13
Att2 Illustrations - 1 to 25
Att3 Photos - 1 to 12
Att4 Accepted NRTL Report – Pages 1 to 21

PRODUCTS

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks, with spring force connection, for DIN-rail mounting, for use with insulated solid or stranded copper wire:

Catalogue number	Voltage [V]	Group	Current [A]	Wire-Range [AWG]	Strip length [mm]	Remarks
WTP 2,5/4 ..	600	C	20	24-12	11	Feed-Through
WTP 2,5/4 PE				24-12	11	PCTB
WTP 2,5/4 D1/2 ..	600	C	20	24-12	11	Double Feed-Through (1X2)
WTP 2,5/4 D1/2 PE				24-12	11	PCTB
WTP 2,5/4 D2/2 ..	600	C	20	24-12	11	Double Feed-Through (2X2)
WTP 2,5/4 D2/2 PE				24-12	11	PTCB
WTP 2,5/4 E ..	300	C	20	24-12	11	Multi-Tier
WTP 2,5/4 E PE				24-12	11	PCTB
IVB WKF 2,5-#	600	C	20	N/A	N/A	Jumper (accessory)
WTP 6/10 ..	600	C	41	12-8	15	Feed-Through
WTP 6/10 PE				12-8	15	PCTB
IVB WKFN 6-#	600	C	41	N/A	N/A	Jumper (accessory)

Where .. (double dot) denotes color, except PE.

Where PE denotes PCTB

Where # denotes number of pins

This report shall not be reproduced, except in full, without the approval of CSA Group.

Notes:

1. Certified as a component for use only where the suitability of the final combination is determined in the end use.
2. Suffixes may be added to the Catalogue numbers to denote color, and mechanical variations not affecting the electrical properties.
3. Not approved for interrupting current.

APPLICABLE REQUIREMENTS

- | | |
|----------------------|--|
| CSA C22.2 No. 0-10 | – General requirements - Canadian electrical code, part II |
| CSA C22.2 No. 158-10 | – Terminal Blocks |